


FLOW PROCESS



SPECIFICATION BA-25

Design Flow	25 m ³ /day
Influent BOD	300 mg/Lt
Effluent BOD	20 mg/Lt
Tank Weight	1430 kg
Operation Weight	20352 kg

EFFECTIVE CAPACITY

Sedimentation And Separation Chamber	4.041 m ³
Anaerobic Contact Media Chamber	6.779 m ³
Moving Bed Chamber	4.187 m ³
Sedimentation Chamber	3.495 m ³
Disinfectant Chamber	0.420 m ³

ATTACHMENTS SPECIFICATION

Equipment Name	Voltage	Bore mm	Capacity Lt/min	Motor W	Qty	Pressure /Head
Blower	220	20	200	190	2	20 kPa

MANHOLE SPECIFICATION

Loading Capacity T-0			
Mark	Measurement	Qty	Note
K1	FRP Manhole ϕ 600	3	By Daiki Axis
K2	FRP Manhole 600x1000	2	By Daiki Axis

INTERIOR PARTS SPECIFICATION

Waste Water Pipe	PVC D or AW
Air Pipe	PVC AW
Air Valve	PVC AW
Pipe Support	FRP

NOTE

NOTE :

— ALL DIMENSIONS ARE IN MM

REFERENCE :

LEGEND :



PROJECT NAME :

DRAWING TITLE :

STP
FLOW DIAGRAM & SPECIFICATION

NAME OF PLANT :

BA-25
(CAP. 25 m³ / day)


FILE NAME	-	
DATE	-	
DRAWING NO.	SCALE	SHEET NO.
-	NTS	1 of 2

AGREEMENT


DRAWN BY	20/05/20	RAYHAN
CHECKED BY	20/05/20	DEDI
APPROVED BY	20/05/20	MURAKAMI

REVISION


NO.	REV	DATE	DESCRIPTION	DRAWN
1	B	20/05/20	Design	RAYHAN
2				
3				




UPPER SECTION



UPPER VIEW



A-A SECTION



B-B SECTION

NOTE

NOTE :

- ALL DIMENSIONS ARE IN MM

REFERENCE :

LEGEND :

Plaza Kaya 3rd Floor
 Jl. HR. Rasjidian Sateh I No. 20 B
 Bukit Duri, Tegal, Indonesia 52000
 Telp : 021-6250108, 6270652
 Faks : 021-6250064
Daiki O
AXIS INDONESIA
PT. DAIKI AXIS INDONESIA

PROJECT NAME :

DRAWING TITLE :

STP
LAYOUT & SECTION

NAME OF PLANT :

BA-25
(CAP. 25 m3 / day)

FILE NAME	-	
DATE	-	
DRAWING NO.	SCALE	SHEET NO.
-	NTS	2 of 2

AGREEMENT

DRAWN BY	20/05/20	RAYHAN
CHECKED BY	20/05/20	DEDI
APPROVED BY	20/05/20	MURAKAMI

REVISION

NO.	REV	DATE	DESCRIPTION	DRAWN
1	B	20/05/20	Design	RAYHAN
2				
3				