


FLOW PROCESS



SPECIFICATION BJ-6

Design Flow	6 m3/day
Influent BOD	300 mg/L
Influent Ammonia	50 mg/L
Effluent BOD	20 mg/L
Effluent Ammonia	10 mg/L
Tank Weight	860 kg
Operation Weight	9505 kg

EFFECTIVE CAPACITY

Sedimentation And Separation Chamber	2.938 m3
Anaerobic Contact Media Chamber	2.720 m3
Moving Bed Chamber	1.683 m3
Sedimentation Chamber	1.265 m3
Disinfectant Chamber	0.059 m3

EQUIPMENT SPECIFICATION

Equipment Name	Voltage	Bore mm	Capacity L/min	Motor W	Qty	Pressure /Head
Blower	220	20	150	155	1	20 kPa

MANHOLE SPECIFICATION

Loading Capacity T-0			
Mark	Measurement	Qty	Note
K1	FRP Manhole ϕ 600	3	By Daiki Axis

INTERIOR PARTS SPECIFICATION

Waste Water Pipe	PVC, 0.6 or 1.0 MPa
Air Pipe	PVC, 1.0 MPa
Air Valve	PVC, 1.0 MPa
Pipe Support	FRP

NOTE

NOTE :

— ALL DIMENSIONS ARE IN MM

REFERENCE :

LEGEND:



PROJECT NAME :

DRAWING TITLE :

STP
FLOW DIAGRAM & SPECIFICATION


NAME OF MODEL :

BJ-6
(CAP. 6 m3 / day)

FILE NAME	-	
DATE	-	
DRAWING NO.	SCALE	SHEET NO.
-	NTS	1 of 2

AGREEMENT		
DRAWN BY	24/09/20	DEDI
CHECKED BY	24/09/20	MURAKAMI
APPROVED BY	24/09/20	SAEKI

REVISION			
REV	DATE	DESCRIPTION	DRAWN
0	03/08/21	Design	DEDI



NOTE

NOTE :

LEGEND:

DaiKi
AXIS
AXIS INDONESIA
PT. DAIKI AXIS INDONESIA

DRAWING TITLE :

STP
LAYOUT & SECTION

BJ-6
(CAP. 6 m3 / day)